


UNDERTAKING

I, **Ramanjeet Kaur**, Principal of **Ascend Education Academy**, hereby undertake and affirm that the water supply and sanitation facilities of the school are fully compliant with the prescribed norms and requirements of the competent authority.

I further state that the drinking water provided to students and staff is safe and fit for consumption, and the water quality test report issued by an authorized laboratory is enclosed herewith for reference.

I take complete responsibility for maintaining the required standards of water safety and sanitation in the school at all times.


Dyalsim ਸਰਪੰਚ
ਕ੍ਰਮ ਪੰਚਾਇਤ ਅਕਬਰਪੁਰ ਅਫਗਾਨਾ
ਬਲਾਕ ਭੁਨਰਹੋੜੀ (ਪਟਿਆਲਾ)

Place: Akbarpur

Sarpanch

Date: 12/01/2026

Signature: 

Name: RAMANJEET KAUR

Designation: Principal

School Seal

Principal
Ascend Education Academy
Akbarpur Distt. Patiala



IMARAT ENGINEERING LABS PRIVATE LIMITED

(ENVIRONMENTAL DIVISION)
(NABL ACCREDITED LAB)

SCF-29, S.S.T. Nagar, Patiala. (Mob.) 81959-54598, 98140-04598
Email: imaratenv@gmail.com



TEST REPORT

Ref No. ULR No. : TC149682610000158F

Dated 12/01/2025

Discipline: Chemical

Product Group: Water

Customer's Name and address:
★ Ascend Education Academy, Village
Akbarpur Afgana, PO. Dudhan Sadhan,
Distt. Patiala, Punjab-147105
Kind Atten:
Email:

Sample receipt date : 02/01/2026
Date of Testing : 02/01/2026 to 12/01/2026
Report Issue Date : 12/01/2026
Reference No. : Nil
Location of testing : Environment section, IEL
Name of work : N.A.

SAMPLE PARTICULARS

Name of Sample : Drinking Water
Description of sample : Liquid Sample in a plastic bottle
Sample quantity : 2 Liter
Sample condition : O.K.
Sample identification No./Batch No. : 150
Sample collected/ submitted/drawn by : Sample submitted by customer
Location/ source of sample : N.A.
Sampling procedure : N.A.
Environmental conditions during sampling : N.A.
Environmental conditions during Testing : Temp. = 25.7°C, R.H. = 56%

TEST RESULT

S.No.	Parameter(s)	Test method	Test Results	Limits as per IS 10500: 2012, RA: 2023	
				Acceptable Limits	Permissible Limits**
1.	Color, CU	IS 3025 (Part 4): 2021	1.98	5	15
2.	Odour	IS 3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable
3.	Turbidity, NTU	IS: 3025 (Part 10): 2023	<1	1	5
4.	pH@25°C	IS: 3025 (Part 11): 2022	7.4	6.5-8.5	No Relaxation
5.	Total Dissolved Solids, mg/L	IS: 3025 (Part 16): 2023	138	500	2000
6.	Total Hardness, mg/L	IS: 3025 (Part 21): 2009, RA: 2019	173	200	600
7.	Sulfide as S ²⁻ , mg/L	APHA 24 th Edition 4500 (Part F):	<0.05	0.05	No Relaxation

Page 1 of 2

1. This report refers only to the specifications upon submitted for testing.
2. Results are valid at the time of testing and under the stated conditions of the lab.
★ Indicates the information Provided by Customer

3. This report shall not be reproduced, except in full, without the written permission of the lab.
4. This report is NOT for any legal purposes.



IMARAT ENGINEERING LABS PRIVATE LIMITED

(ENVIRONMENTAL DIVISION)

(NABL ACCREDITED LAB)

SCF-29, S.S.T. Nagar, Patiala. (Mob.) 81959-54598, 98140-04598
Email: imaratenv@gmail.com



TEST REPORT

Ref No. ULR No. : TC149682610000158F

Dated 12/01/2025

		2023			
8.	Chloride as Cl, mg/L	IS 3025 (Part 32): 1988, RA: 2019	20	250	1000
9.	Ammoniacal Nitrogen, mg/L	IS: 3025 (Part 34/sec 1): 2023	< 0.5	0.5	No Relaxation
10.	Nitrate Nitrogen, mg/L	APHA 24 th Edition 4500-NO ₃ ⁻ (Part B): 2023	1.1	45	No Relaxation
11.	Magnesium as Mg, mg/L	APHA 3500- Mg (Part B): 2023	8	30	100
12.	Calcium (Ca ⁺), mg/L	IS: 3025 (Part 40): 2024	32	75	200
13.	Electrical Conductivity, μ S/cm	IS: 3025 (Part 14): 2023	255	--	--

(Note: "*" represents Permissible Limits in the absence of Alternate Source)

-----End of the Report-----

Authorized signatory
Er. Rishi Garg
(Quality Manager)



Certificate & Scope



Report Copy



Page 2 of 2

1. This report refers only to the particulars item submitted for testing.
3. Results are valid at the time of testing and under the stated conditions of the lab.
★ indicates the information provided by Customer

2. This report shall not be resold, except in full, without the written permission of the lab.
4. This report is NOT for any legal purposes.